

**COUNTY OF SONOMA
DEPARTMENT OF TRANSPORTATION
AND PUBLIC WORKS
2300 COUNTY CENTER DRIVE, SUITE B 100
SANTA ROSA, CA 95403**

PHILLIP M. DEMERY, DIRECTOR



AREA CODE (707)
ROADS.....565-2231
TRANSIT.....585-7516
REFUSE.....565-7940
AIRPORT.....565-7243
AIR POLLUTION.....433-5911
FAX.....565-2620
www.sonoma-county.org

November 23, 2009

NOTICE TO PLANHOLDERS
FOR CONSTRUCTION OF
FEDERAL AID PROJECT NO. CML-5920 (112)
WESTERN AVENUE
BIKE SHOULDER WIDENING
COUNTY PROJECT NO. C03020

CLARIFICATION NO. 1

Section 10-1.23, B., RELOCATE PRIVATE WATER SERVICE LINES, is clarified with the following:

The locations of the existing private water lines are unknown, but are expected to be outside the easterly side of the roadway within the County right of way. For purposes of bidding, the Contractor should expect to replace the water lines in a joint trench per City of Petaluma Water System Design and Construction Standards within three feet of the easterly County right of way line.

Restoration of the existing roadway concrete base in trenches is clarified with the following:

There is an existing concrete base within the roadway that is covered with a varying depth of asphalt. Concrete base that is removed for trench excavation shall be replaced with a matching depth of minor concrete (5-sack).

Original Signed

Levi Gurule, P.E.