

COUNTY OF SONOMA
DEPARTMENT OF TRANSPORTATION
AND PUBLIC WORKS
2300 COUNTY CENTER DRIVE, SUITE B 100
SANTA ROSA, CALIFORNIA 95403

Phillip M. Demery, Director



AREA CODE (707)

ROADS..... 565-2231
TRANSIT 585-7516
REFUSE 565-7940
AIRPORT..... 565-7243
AIR POLLUTION..... 433-5911
FAX..... 565-2620

www.sonomacounty.org/tpw

April 2, 2010

NOTICE TO PLANHOLDERS

FOR CONSTRUCTION OF

CHARLES M. SCHULZ – SONOMA COUNTY AIRPORT

PAVEMENT PRESERVATION – TAXIWAYS D & Y

COUNTY PROJECT NO. WO 9590

ADDENDUM NO. 3

1. CHANGES TO TECHNICAL SPECIFICATIONS

- A. **DIVISION V, TECHNICAL SPECIFICATIONS, ITEM P-620, RUNWAY AND TAXIWAY PAINTING** – Page 7, First paragraph. Insert the following after the third sentence in the first paragraph:

“Temporary paint markings (1st coat of paint striping) shall be applied to the asphalt concrete after the seal coat has cured for 24 hours. Temporary paint striping shall not receive glass beads. No separate measurement or payment shall be made for temporary paint markings. A period of 14 days shall elapse between placement of the seal coat and the final application of paint (second coat).”

- B. **B. DIVISION V, TECHNICAL SPECIFICATIONS, ITEM P-609A, ASPHALT REJUVENATING SEAL** – Insert the following in Section 609-2.1, Paragraph A. Replace the first sentence with the following:

“A. Test Sections. At least three (3) working days prior to full production, the Contractor shall place a series of 3 feet wide by 25 feet long test sections at minimum application rates of 0.10, 0.12, 0.14, etc., gallons per square yard as needed to evaluate each pavement type.”

- C. **DIVISION V, TECHNICAL SPECIFICATIONS, ITEM P-609A, ASPHALT REJUVENATING SEAL** – Insert the following in Section 609-3.2:

“609-3.2 POLYMER. The vinyl acrylic polymer shall be approved for use by the manufacturer of the bituminous material for compatibility and shall meet the following properties.

Solids content, percent by weight	54 to 57 percent
Weight per gallon	8.90 to 9.80 lbs
pH	4.0 to 6.0
Particle charge	Nonionic/Anionic
Mechanical stability	Excellent
Minimum film forming temperature, °C	+5
Tg °C	22 max.

The Contractor shall submit manufacturer’s specifications for vinyl acrylic polymer for review and approval with the bituminous materials submittal.”

Please fill out the Addendum Acknowledgement sheet on page 3 of the Proposal Packet verifying your receipt of this Addendum and submit with your bid.

original signed

 Susan Klassen, Deputy Director
 Department of Transportation & Public Works